

1. AVOIDANCE CONDITION FOR AREA SOURCES SUBJECT TO 40 CFR 63 Subpart JJJJJ (6J) – In accordance with 15A NCAC 2Q .0317, the Permittee is avoiding applicability of 40 CFR 63 Subpart JJJJJ (6J) “Industrial, Commercial, and Institutional Boilers Area Sources.” The Permittee is permitted to operate a natural gas / No. X [Specify fuel oil #] fuel oil-fired boiler (ID Nos. XXX [specify source ID Nos]). Per 40 CFR 63.11195(e), these/this source(s) is/are exempt from this Subpart because they are defined as gas-fired boiler(s) in 40 CFR 63.11237. In order to maintain this exemption, the Permittee is allowed to fire liquid fuel only during periods of gas curtailment, gas supply interruptions, startups, or for periodic testing on liquid fuel (periodic testing not to exceed a combined total of 48 hours during any calendar year).

- a. The Permittee shall maintain records that document the time periods when liquid fuel is fired and the reasons the liquid fuel is fired.
- b. If the Permittee fires liquid fuel for reasons other than gas curtailment, gas supply interruptions, startups, or for periodic testing on liquid fuel, the Permittee is no longer exempt from Subpart JJJJJ (6J). As required by 40 CFR 62.11225(g), the Permittee must provide notice within 30 days of the fuel switch. The notification must identify:
 - i. The name of the owner or operator of the affected source, the location of the source, the boiler(s) that have switched fuels, and the date of the notice.
 - ii. The date upon which the fuel switch occurred.

As required by 40 CFR 63.11210(h), the Permittee must demonstrate compliance within 180 days of the effective date of the fuel switch.